

उप कमाण्डेन्ट का कार्यालय
केन्द्रीय औद्योगिक सुरक्षा बल
(गृह मंत्रालय)

इकाई सीटीपीएस चन्द्रपुरा
जिला: बोकारो (झारखण्ड)
दिनांक 18/05/2021

पत्राक सं० ई-42099/ केओसुब/सीटीपीएस/अग्नि/2021/364

To

The Principal
Kendriya Vidyalaya,
DVC CTPS Chandrapura.

Sub: **FIRE SAFETY CERTIFICATE :REG**

Kindly refer to DVC/CTPS Chandrapura letter No. CT/CE/Safety-Misc/176 Dated 18.05.2021 & KV CTPS Chandrapura Ref. 1-10/KVC-2019-20/60 Dated 25.02.2021 on the subject cited above.

02. In this regard, it is hereby informed that CISF Fire Wing is checking all the First Aid Firefighting Equipments installed at school campus as per the schedule and specially prevention team visited on 18.05.2021 and made the following observation in respect of fire safety:-

- i) Kendriya Vidyalay, Chandrapura is having existing building comprising of ground & one upper floor.
- ii) Building has access for the fire tender and for engine.
- iii) The details of deployment of First Aid Fire fighting Equipments is as under.
 - a) CO₂ Extinguishers (Capacity -02 kg) - 05 Nos.
 - b) CO₂ Extinguishers (Capacity -3.2 kg) - 01 No.
 - c) CO₂ Extinguishers (Capacity -4.5kg) - 07 Nos.
- iv) One under ground water static tank having capacity of about 30,000 Litres has been provided inside the premises.

During checking of First Aid Firefighting Equipments all the installed Fire extinguishers are found in working condition.


18/5/21
उप कमाण्डेन्ट / अग्नि
केओसुब इकाई सीटीपीएस चन्द्रपुरा
CISF Unit CTPS, Chandrapura